

QNE-01_ (01 - 08)

Laboratório_(2º Pavto)

CIRCUITO	TOMADAS (Watts)						CARGA WATTS	TENSÃO VOLTS	CORRENTE AMPERES	DISJUNTOR AMPERES	CONDUTOR mm2	INDICAÇÃO DO USO
	Tomadas de uso geral			Uso Especifico								
	300w	500w	900w	2000w	2580w	3500w						
01		5					2500	220	11.36	20	#4,0	Tomadas Bancada L - 10 A
02		5					2500	220	11.36	20	#4,0	Tomadas Bancada L - 10 A
03					1		2560	220	11.63	25	#4,0	Tomadas Bancada L - 20 A
04		5					2500	220	11.36	20	#4,0	Tomadas Castelo 1 - 10 A
05		5					2500	220	11.36	20	#4,0	Tomadas Castelo 1 - 10 A
06					1		2560	220	11.63		#4,0	Tomadas Castelo 1 - 20 A
07		5					2500	220	11.36		#4,0	Tomadas Castelo 2 - 10 A
08		5					2500	220	11.36		#4,0	Tomadas Castelo 2 - 10 A
09					1		2560	220	11.63		#4,0	Tomadas Castelo 2 - 20 A
CARGA TOTAL INSTALADA:							15.120W	380	--	35A	3F#6+N#6 T#6	-

